## MECHANICAL, PLUMBING, ELECTRICAL, AND SWIMMING POOL BOARD OF APPEALS MINUTES

## May 9, 2006

Public notice having been posted, a public hearing of the MPE Board was held at 4:00 p.m., Tuesday, May 9, 2006, in the Council Chambers at City Hall, 555 Walnut, Abilene, Texas.

**MPE BOARD MEMBERS PRESENT:** Anthony McColum, Chairman

Phil Miller James Wheeler Ron Smith

STAFF PRESENT: Van Watson

Glen Bailey David Sartor

GUESTS: David Cruddas

- 1. The meeting was called to order by Anthony McColum, Chairman.
- 2. The next item to come before the Board was the approval of the March 14, 2006 minutes. A motion was made by Ron Smith, and seconded by James Wheeler, to approve the minutes as written. Said motion unanimously passed.
- 3. The next matter to come before the Board was consideration, with possible action, regarding the request of William C. Pierce, representative for Abilene Bible Conference Association, to use a Type II Hood, in lieu of a Type I Hood, at their facility located at 3125 Oldham Lane, Abilene, Texas. Van Watson, Assistant Building Official, addressed the Board, advising them this building was previously occupied by the Girl Scouts Council, and, at that time, the Board approved a Type II hood could be used in lieu of a Type I hood. He further stated that the Abilene Bible Conference Association was not making any changes and was making the same request as the previous owners to use the Type II hood. David Cruddas, representative for the Abilene Bible Conference Association, addressed the Board and said they understand that the sign has to be posted stating "FRYING, GRILLING, SAUTEEING AND/OR BROILING ARE PROHIBITED BY CITY ORDINANCE". James Wheeler made a motion to approve this request. The motion was seconded by Ron Smith and unanimously passed.
- 4. Upon motion made and seconded, the meeting adjourned.

Anthony McColum, Chairman	Alice Adams, Acting Secretary

Filename: 2006-05-09 Minutes MPE Bd.doc

Directory: C:\Documents and Settings\scott.a.hughes\Local

Settings\Temporary Internet Files\OLK9E1

Template: C:\Documents and Settings\scott.a.hughes\Application

Data\Microsoft\Templates\Normal.dot

Title: MECHANICAL, PLUMBING, ELECTRICAL, AND

**SWIMMING POOL** 

Subject:

Author: AdamsA

Keywords: Comments:

Creation Date: 5/9/2006 1:34:00 PM

Change Number: 7

Last Saved On: 5/9/2006 4:40:00 PM

Last Saved By: adamsa
Total Editing Time: 49 Minutes

Last Printed On: 9/5/2006 9:08:00 AM

As of Last Complete Printing

Number of Pages: 1

Number of Words: 324 (approx.) Number of Characters: 1,708 (approx.)