

RESOLUTION NO. 53-1992

A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF ABILENE, TEXAS,  
APPROVING AN AMENDMENT TO THE *MINIMUM STANDARDS FOR AERONAUTICAL  
ACTIVITIES* AT THE ABILENE REGIONAL AIRPORT

WHEREAS, the City Council by Oral Resolution during the March  
10, 1988, Council Meeting adopted the *Minimum Standards for  
Aeronautical Activities* at the Abilene Regional Airport;

WHEREAS, a need has arisen to amend the *Minimum Standards* as  
per the attached Exhibit A.

NOW THEREFORE, BE IT RESOLVED BY THE CITY COUNCIL OF THE CITY OF  
ABILENE, TEXAS:


Part 1: That amending the *Minimum Standards for Aeronautical  
Activities* at the Abilene Regional Airport as per attached Exhibit  
A is hereby in all things approved.

Part 2: That this Resolution shall become effective  
immediately from and after its passage.

ADOPTED this 5th day of November, A. D., 1992.

ATTEST:

  
\_\_\_\_\_  
City Secretary

  
\_\_\_\_\_  
Mayor

APPROVED:

  
\_\_\_\_\_  
City Attorney

00252

MINIMUM STANDARDS FOR AERONAUTIC ACTIVITIES

AT THE ABILENE REGIONAL AIRPORT

Amend the Minimum Standards for Aeronautical Activities at the Abilene Regional Airport dated March 10, 1988, as follows:

Remove the first paragraph on Page 12 of Section E. 2. (c), which reads:

The Operator shall provide at least two (2) 10,000 gallon fuel storage tanks at the Abilene Municipal Airport and maintain an adequate supply of fuel on hand at all times of at least two (2) grades of fuel as closely related as possible to the popular demand of the general aviation users of the Airport. The Operator shall provide at least two (2) metered filter-equipped dispensers, fixed or mobile, for dispensing the minimum requirements of two (2) grades of fuel.

Replace with:

The Operator shall provide a minimum capacity of 10,000 gallons for each type of fuel at the Abilene Regional Airport. These fuels shall be stored in fixed/permanent storage tanks. The Operator shall maintain an adequate supply of fuel on hand at all times of at least two (2) grades of fuel as closely related as possible to the popular demand of the general aviation uses of the airport. The Operator shall provide at least two (2) metered filter-equipped dispensers, fixed or mobile, for dispensing the minimum requirements of two (2) grades of fuel.